



## Kimberly-Clark BLOCK-IT\* House Wrap Flammability Test

Kimberly-Clark BLOCK-IT\* House Wrap Receives Class A Flammability rated per ASTM E84.

SUMMARY: FLAME SPREAD: 0 SMOKE DEVELOPED: 20

**SUMMARY OF ASTM E84 RESULTS:** Because of the possible variations in reproducibility, the results are adjusted to the nearest figure divisible by 5. Smoke Density values over 200 are rounded to the nearest figure divisible by 50.

In order to obtain the Flame Spread Classification, the above results should be compared to the following table:

NFPA CLASS	<b>IBC CLASS</b>	FLAME SPREAD	SMOKE DEVELOPED
Α	A	0 through 25	Less than or equal to 450
В	В	26 through 75	Less than or equal to 450
С	С	76 through 200	Less than or equal to 450
BUILDING CODES CITED:			

- 1. National Fire Protection Association, ANSI/NFPA No. 101, "Life Safety Code".
- 2. International Building Code, Chapter 8, Interior Finishes, Section 803.